



Bureau Veritas Asset Integrity and Reliability Services Pty Ltd
ABN 86 000 928 816
35-37 Stirling Street Thebarton SA 5031
Phone: +61 (0)8 8416 5200
www.bureauveritas.com.au

7 January, 2019

1414°
Level 4, 81 Flinders St
Adelaide SA 5000

Attention: Isaac Mathwin

REPORT

2869275-Metal-1

CLIENT REFERENCE:

PO 0191

TITLE:

Third Party Audit

SAMPLE IDENTIFICATION:

10MWhr TESS-IND, located at Southlink Industrial Park, Lonsdale

WORK REQUESTED:

Site examination and review test data from runs on 30 October, 7 November and 12 November 2018.

SUMMARY:

Test data from the unit shows the following;
Average output of 104kW over a period of 8 hours (12 Nov 2018).
Average output of 148kW over a period of 3 hours (30 Oct 2018).
Maximum PCM temperature 1418°C (7 Nov 2018).

INVESTIGATING OFFICER(S):

Monty Luke

Monty Luke
Bureau Veritas Adelaide